

White, Emma

From: Health & Safety Service Team (Animal Welfare)
Sent: 04 July 2016 09:46
To: White, Emma
Subject: RE: Thomas Osbourne LS8 1AP

Emma

PREM/03032/016

I've written to the applicant advising them that I am objecting to the removal of certain conditions, as requested in their variation. Specifically, the removal of :-

33. WRITTEN RECORDS OF ALL ACCIDENTS AND SAFETY INCIDENTS INVOLVING MEMBERS OF THE PUBLIC WILL BE KEPT. THESE WILL BE MADE AVAILABLE AT THE REQUEST OF AN AUTHORISED OFFICER.

34. A SUITABLY TRAINED AND COMPETENT PERSON MUST ENSURE REGULAR SAFETY CHECKS OF THE PREMISES INCLUDING DECORATIVE AND FUNCTIONAL FIXTURES, FLOOR SURFACES AND EQUIPMENT (INCLUDING ELECTRICAL APPLIANCES) TO WHICH THE PUBLIC MAY COME INTO CONTACT ARE UNDERTAKEN. RECORDS OF THESE SAFETY CHECKS MUST BE KEPT AND MADE AVAILABLE BY AUTHORISED OFFICER.

36. ELECTRICAL INSTALLATIONS WILL BE INSPECTED ON A PERIODIC BASIS (AT LEAST EVERY 3 YEARS OR AT A FREQUENCY SPECIFIED IN WRITING) BY A SUITABLY QUALIFIED AND COMPETENT PERSON. IF USED, ANY TEMPORARY ELECTRICAL WIRING AND DISTRIBUTIONS WILL ALSO BE INSPECTED. INSPECTION RECORDS / CERTIFICATES WILL BE KEPT. THESE WILL BE MADE AVAILABLE AT THE REQUEST OF AN AUTHORISED OFFICER.

37. ONE OF THE FOLLOWING PROTECTIVE MEASURES SHALL BE USED FOR ALL SOCKET-OUTLETS WHICH MAY BE USED FOR THE CONNECTION FOR LIGHTING, VIDEO OR SOUND AMPLIFICATION EQUIPMENT AND DISPLAY MODELS;

A) EACH SOCKET-OUTLET CIRCUIT SHALL BE PROTECTED BY A RESIDUAL CURRENT DEVICE HAVING A RATED RESIDUAL OPERATING CURRENT NOT EXCEEDING 30mA,

OR

B) EACH INDIVIDUAL SOCKET-OUTLET SHALL BE PROTECTED BY AN INTEGRAL RESIDUAL CURRENT DEVICE HAVING A RATED RESIDUAL OPERATING CURRENT NOT EXCEEDING 30mA.